



Academy of Hope PCS (Northeast Campus) - Lead in Water Test Results



FY23 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Academy of Hope PCS [Northeast Campus]	WS-067-001	Cooler	1	In hallway adjacent to restrooms		Left	WF-012023-067001-06	N/A	FT-FY23-012023-067001-A	Non-operational	FT-FY23-012023-067001-B	Non-operational
Academy of Hope PCS [Northeast Campus]	WS-067-002	Cooler	1	In hallway adjacent to restrooms		Right	WF-012023-067002-06	N/A	FT-FY23-012023-067002-A	Non-operational	FT-FY23-012023-067002-B	Non-operational
Academy of Hope PCS [Northeast Campus]	WS-067-003	Break Room	2	In staff break room			WF-012023-067003-06	4/4/23	FT-FY23-012023-067003-A	<1	FT-FY23-012023-067003-B	<1
Academy of Hope PCS [Northeast Campus]	WS-067-004	Cooler	2	In hallway adjacent to staff break room			WF-012023-067004-06	4/4/23	FT-FY23-012023-067004-A	<1	FT-FY23-012023-067004-B	<1
Academy of Hope PCS [Northeast Campus]	WS-067-005	Cooler	2	In hallway adjacent to staff break room		Right	WF-012023-067005-06	4/4/23	FT-FY23-012023-067005-A	<1	FT-FY23-012023-067005-B	<1
Academy of Hope PCS [Northeast Campus]	WS-067-006	Cooler	Ground	In all purpose room	High	Left	WF-012023-067006-06	N/A	FT-FY23-012023-067006-A	Non-operational	FT-FY23-012023-067006-B	Non-operational
Academy of Hope PCS [Northeast Campus]	WS-067-007	Cooler	Ground	In all purpose room	Low	Right	WF-012023-067007-06	N/A	FT-FY23-012023-067007-A	Non-operational	FT-FY23-012023-067007-B	Non-operational
Academy of Hope PCS [Northeast Campus]	WS-067-008	Break Room	Ground	In all purpose room in pantry G-07			WF-012023-067008-06	4/4/23	FT-FY23-012023-067008-A	<1	FT-FY23-012023-067008-B	<1
Academy of Hope PCS [Northeast Campus]	WS-067-009	Cooler	1	In hallway adjacent to office 130		Left	WF-012023-067009-06	4/4/23	FT-FY23-012023-067009-A	<1	FT-FY23-012023-067009-B	<1
Academy of Hope PCS [Northeast Campus]	WS-067-010	Cooler	1	In hallway adjacent to office 130		Right	WF-012023-067010-06	4/4/23	FT-FY23-012023-067010-A	<1	FT-FY23-012023-067010-B	<1